

Drinking Water Quality Certification – July 2016

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 8071
Reference: 28-24
Date Sampled: 07 Jul 2016
Date Reported: 18 Jul 2016

Regulations: SI 122 of 2014 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	20551	<1	<1	3.80	3.80
Andy Price	20552	<1	<1	3.60	3.60
Creche	20553	<1	<1	0.08	0.08
Michael Hogan	20554	<1	<1	1.20	1.20
School/Hall	20555	<1	<1	1.50	1.50
Sheedy's Shop	20556	<1	<1	1.20	1.20

Drinking Water Quality Rating: Free chlorine levels are extremely high; please ensure to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.