

### **Drinking Water Quality Certification – January 2024**

Killone GWS,  
Imleach,  
Barntick,  
Ballynacally,  
Co. Clare.

**Report No:** 11152  
**Reference:** 40-196  
**Date Sampled:** 17 Jan 2024  
**Date Reported:** 20 Jan 2024

**Regulations:** SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

| Sample Location | Sample No. | Total Coliforms No./100 mL | <i>E. coli</i> No./100 mL | Free Chlorine mg/L | Total Chlorine mg/L |
|-----------------|------------|----------------------------|---------------------------|--------------------|---------------------|
| Pat Haren       | 32648      | <1                         | <1                        | 0.36               | 0.30                |
| R Murphy        | 32649      | <1                         | <1                        | 0.48               | 0.48                |
| Michael Hogan   | 32650      | <1                         | <1                        | 0.18               | 0.18                |
| School          | 32651      | <1                         | <1                        | 0.09               | 0.09                |
| Londis Shop     | 32652      | <1                         | <1                        | 0.06               | 0.06                |
| Banner Steel    | 32653      | <1                         | <1                        | 0.09               | 0.09                |

**Comment:** No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan  
Amberley Water Solutions Ltd.