

## **Drinking Water Quality Certification – June 2022**

Killone GWS,  
Imleach,  
Barntick,  
Ballynacally,  
Co. Clare.

**Report No:** 10325  
**Reference:** 37-191  
**Date Sampled:** 17 Jun 2022  
**Date Reported:** 26 Jun 2022

**Regulations:** SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	29193	<1	<1	0.19	0.19
R Murphy	29194	<1	<1	0.44	0.49
Michael Hogan	29195	<1	<1	0.44	0.47
School	29196	<1	<1	0.05	0.05
Londis Shop	29197	<1	<1	0.12	0.13
Banner Steel	29198	<1	<1	0.09	0.09

**Comment:** No Coliforms or *E. coli* were detected in the samples tested. It is recommended to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan  
Amberley Water Solutions Ltd.