

Drinking Water Quality Certification – January 2023

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 10648
Reference: 39-28
Date Sampled: 04 Jan 2023
Date Reported: 07 Jan 2023

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	30242	<1	<1	0.22	0.22
R Murphy	30243	<1	<1	0.44	0.45
Michael Hogan	30244	<1	<1	0.40	0.41
School	-	-	-	-	-
Londis Shop	30246	<1	<1	0.30	0.31
Banner Steel	30247	<1	<1	0.22	0.23

Comment: No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

School closed at time of sampling

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.