

Drinking Water Quality Certification – May 2016

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 8017
Reference: 27-155
Date Sampled: 20 May 2016
Date Reported: 29 May 2016

Regulations: SI 122 of 2014 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	20406	<1	<1	0.13	0.13
Andy Price	20407	<1	<1	0.13	0.13
Creche	20408	<1	<1	0.15	0.15
Michael Hogan	20409	<1	<1	0.13	0.13
School/Hall	20410	<1	<1	0.20	0.20
Sheedy's Shop	20411	<1	<1	0.15	0.15

Drinking Water Quality Rating: Please maintain free chlorine at a minimum of 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.