

## **Drinking Water Quality Certification – June 2017**

Killone GWS,  
Imleach,  
Barntick,  
Ballynacally,  
Co. Clare.

**Report No:** 8351  
**Reference:** 29-115  
**Date Sampled:** 21 Jun 2017  
**Date Reported:** 27 Jun 2017

**Regulations:** SI 122 of 2014 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	21838	<1	<1	0.16	0.17
R Murphy	21839	<1	<1	0.17	0.18
Creche	21840	<1	<1	0.16	0.18
Michael Hogan	21841	<1	<1	0.20	0.22
School/Hall	21842	<1	<1	0.17	0.19
Sheedy's Shop	21843	<1	<1	0.13	0.13

**Drinking Water Quality Rating:** Please continue to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan  
Amberley Water Solutions Ltd.