

Drinking Water Quality Certification – September 2020

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 9565
Reference: 35-18
Date Sampled: 04 Sep 2020
Date Reported: 13 Sep 2020

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	26605	<1	<1	0.04	0.06
R Murphy	26606	<1	<1	0.17	0.17
Creche	26607	<1	<1	0.02	0.02
Michael Hogan	26608	<1	<1	0.12	0.17
School/Hall	26609	<1	<1	0.02	0.04
Londis Shop	26610	<1	<1	0.06	0.08

*On Request

Comment: No Coliforms or *E. coli* were detected in the samples tested. Please ensure to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.