

## **Drinking Water Quality Certification – October 2016**

Killone GWS,  
Imleach,  
Barntick,  
Ballynacally,  
Co. Clare.

**Report No:** 8164  
**Reference:** 28-102  
**Date Sampled:** 19 Oct 2016  
**Date Reported:** 23 Oct 2016

**Regulations:** SI 122 of 2014 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	20963	<1	<1	0.09	0.09
Andy Price*	20964	<1	<1	0.20	0.20
Creche	20965	<1	<1	0.16	0.19
Michael Hogan	20966	<1	<1	0.19	0.19
School/Hall	20967	<1	<1	0.16	0.16
Sheedy's Shop	20968	<1	<1	0.16	0.16

\*This sample was taken from R Murphy's House

**Drinking Water Quality Rating:** Please continue to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan  
Amberley Water Solutions Ltd.