

Drinking Water Quality Certification – June 2016

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 8040
Reference: 28-8
Date Sampled: 13 June 2016
Date Reported: 18 Jun 2016

Regulations: SI 122 of 2014 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	20445	<1	<1	0.24	0.24
Andy Price	20446	<1	<1	0.24	0.30
Creche	20447	<1	<1	0.17	0.17
Michael Hogan	20450	<1	<1	0.30	0.30
School/Hall	20448	<1	<1	0.20	0.24
Sheedy's Shop	20449	<1	<1	0.20	0.20

Drinking Water Quality Rating: Please maintain free chlorine at a minimum of 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.