

Drinking Water Quality Certification – April 2022

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 10237
Reference: 37-116
Date Sampled: 07 Mar 2022
Date Reported: 10 Apr 2022

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	28843	<1	<1	0.16	0.16
R Murphy	28844	<1	<1	0.40	0.44
Michael Hogan	28845	<1	<1	0.40	0.45
School/Hall	28846	<1	<1	0.37	0.38
Londis Shop	28847	<1	<1	0.23	0.23

Comment: No Coliforms or *E. coli* were detected in the samples tested. It is recommended to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.