

## **Drinking Water Quality Certification – August 2017**

Killone GWS,  
Imleach,  
Barntick,  
Ballynacally,  
Co. Clare.

**Report No:** 8423  
**Reference:** 30-6  
**Date Sampled:** 17 Aug 2017  
**Date Reported:** 23 Aug 2017

**Regulations:** SI 122 of 2014 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	22117	<1	<1	0.10	0.16
R Murphy	22118	<1	<1	0.16	0.23
Creche	22119	<1	<1	0.10	0.13
Michael Hogan	22120	<1	<1	0.15	0.20
School/Hall	22121	<1	<1	0.13	0.16
Sheedy's Shop	22122	<1	<1	0.15	0.17

**Drinking Water Quality Rating:** Please ensure to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan  
Amberley Water Solutions Ltd.