

Drinking Water Quality Certification – April 2019

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 9014
Reference: 32-128
Date Sampled: 11 Apr 2019
Date Reported: 14 Apr 2019

Regulations: SI 122 of 2014 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	24497	<1	<1	0.17	0.19
R Murphy	24498	<1	<1	0.24	0.29
Creche	24499	<1	<1	0.16	0.17
Michael Hogan	24500	<1	<1	0.24	0.28
School/Hall	24501	<1	<1	0.21	0.23
Sheedy's Shop	24502	<1	<1	0.18	0.20

Drinking Water Quality Rating: Please continue to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.