

Drinking Water Quality Certification – November 2025

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 12010
Reference: 44-20
Date Sampled: 13 Nov 2025
Date Reported: 15 Nov 2025

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	36608	<1	<1	0.30	0.40
R Murphy	-	-	-	-	-
Michael Hogan	36610	<1	<1	0.04	0.05
School	36611	<1	<1	0.02	0.04
Londis Shop	36612	<1	<1	0.05	0.10
Banner Steel	36613	<1	<1	0.17	0.21

Comment: No Flow at Rory Murphys House.

It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.