

Drinking Water Quality Certification – February 2019

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 8949
Reference: 32-86
Date Sampled: 20 Feb 2019
Date Reported: 23 Feb 2019

Regulations: SI 122 of 2014 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	24290	<1	<1	0.12	0.16
R Murphy	24291	<1	<1	0.27	0.30
Creche	24292	<1	<1	0.10	0.12
Michael Hogan	24293	<1	<1	0.23	0.28
School/Hall	24294	<1	<1	0.06	0.09
Sheedy's Shop	24295	<1	<1	0.06	0.09

Drinking Water Quality Rating: Please ensure to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.