

Drinking Water Quality Certification – March 2018

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 8588
Reference: 31-7
Date Sampled: 22 Mar 2018
Date Reported: 30 Mar 2018

Regulations: SI 122 of 2014 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	22897	<1	<1	0.24	0.35
R Murphy	22898	<1	<1	0.54	0.60
Creche	22899	<1	<1	0.25	0.33
Michael Hogan	22900	<1	<1	0.57	0.63
School/Hall	22901	<1	<1	0.10	0.14
Sheedy's Shop	22902	<1	<1	0.10	0.14

Drinking Water Quality Rating: Please ensure to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.