

## **Drinking Water Quality Certification – May 2017**

Killone GWS,  
Imleach,  
Barntick,  
Ballynacally,  
Co. Clare.

**Report No:** 8376  
**Reference:** 29-98  
**Date Sampled:** 15 May 2017  
**Date Reported:** 29 May 2017

**Regulations:** SI 122 of 2014 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	21769	<1	<1	0.10	0.13
R Murphy	21770	<1	<1	0.13	0.18
Creche	21771	<1	<1	0.10	0.13
Michael Hogan	21772	<1	<1	0.10	0.13
School/Hall	21773	<1	<1	0.09	0.09
Sheedy's Shop	21774	<1	<1	0.11	0.15

**Drinking Water Quality Rating:** Please ensure to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan  
Amberley Water Solutions Ltd.