

Drinking Water Quality Certification – October 2022

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 10520
Reference: 38-139/165
Date Sampled: 06 Oct 2022
Date Reported: 28 Oct 2022

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	29866	<1	<1	0.23	0.23
R Murphy	29867	<1	<1	0.45	0.50
Michael Hogan	29868	<1	<1	0.33	0.37
School	29869	<1	<1	0.07	0.07
Londis Shop	29870	<1	<1	0.17	0.19
Banner Steel	29871	<1	<1	0.15	0.15

Comment: No Coliforms or *E. coli* were detected in the samples tested. It is recommended to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.