

Drinking Water Quality Certification – September 2016

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 8127
Reference: 28-68
Date Sampled: 09 Sep 2016
Date Reported: 25 Sep 2016

Regulations: SI 122 of 2014 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	20759	<1	<1	0.12	0.12
Andy Price	20760	<1	<1	0.30	0.30
Creche	20761	<1	<1	0.05	0.05
Michael Hogan	20762	<1	<1	0.24	0.24
School/Hall*	20763	<1	<1	0.11	0.11
Sheedy's Shop	20764	<1	<1	0.11	0.11

*This sample was taken from Rory Murphy's House

Drinking Water Quality Rating: Please continue to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.