

## **Drinking Water Quality Certification – November 2016**

Killone GWS,  
Imleach,  
Barntick,  
Ballynacally,  
Co. Clare.

**Report No:** 8194  
**Reference:** 28-126  
**Date Sampled:** 22 Nov 2016  
**Date Reported:** 26 Nov 2016

**Regulations:** SI 122 of 2014 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	21064	<1	<1	0.06	0.06
Andy Price*	21065	<1	<1	0.16	0.20
Creche	21066	<1	<1	0.06	0.10
Michael Hogan	21067	<1	<1	0.10	0.20
School/Hall	21068	<1	<1	0.10	0.20
Sheedy's Shop	21069	<1	<1	0.08	0.10

\*This sample was taken from R Murphy's House

**Drinking Water Quality Rating:** Please ensure to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan  
Amberley Water Solutions Ltd.