

Drinking Water Quality Certification – December 2020

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 9651
Reference: 35-85
Date Sampled: 09 Dec 2020
Date Reported: 13 Dec 2020

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	26947	<1	<1	0.12	0.14
R Murphy	26948	<1	<1	0.14	0.18
Creche	26949	<1	<1	0.05	0.06
Michael Hogan	26950	<1	<1	0.14	0.19
School/Hall	26951	<1	<1	0.07	0.10
Londis Shop	26952	<1	<1	0.07	0.10

*On Request

Comment: No Coliforms or *E. coli* were detected in the samples tested. Please ensure to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.