

## **Drinking Water Quality Certification – September 2025**

Killone GWS,  
Imleach,  
Barntick,  
Ballynacally,  
Co. Clare.

**Report No:** 11943  
**Reference:** 43-114  
**Date Sampled:** 02 Sep 2025  
**Date Reported:** 08 Sep 2025

**Regulations:** SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	36208	2.0	<1	0.01	0.01
R Murphy	36209	<1	<1	0.02	0.03
Michael Hogan	36210	<1	<1	0.01	0.05
School	36211	<1	<1	0.00	0.00
Londis Shop	36212	12.4	<1	0.01	0.01
Banner Steel	36213	<1	<1	0.00	0.00

**Comment:** Very low levels of chlorine detected across the group.

Coliforms were detected at Pat Haran's and Londis shop. Group administrator contacted.

It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan  
Amberley Water Solutions Ltd.