

Drinking Water Quality Certification – May 2024

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 11318
Reference: 41-94
Date Sampled: 02 May 2024
Date Reported: 10 May 2024

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	33377	<1	<1	0.20	0.21
R Murphy	33378	<1	<1	0.40	0.40
Michael Hogan	33379	<1	<1	0.38	0.39
School	33380	<1	<1	0.10	0.10
Londis Shop	33381	<1	<1	0.18	0.18
Banner Steel	33382	<1	<1	0.05	0.05

Comment: No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.