

Drinking Water Quality Certification – June 2020

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 9448
Reference: 34-125
Date Sampled: 23 Jun 2020
Date Reported: 27 Jun 2020

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	26228	<1	<1	0.06	0.06
R Murphy	26229	<1	<1	0.23	0.29
Creche	26230	<1	<1	0.02	0.04
Michael Hogan	26231	<1	<1	0.24	0.26
School/Hall	26232	<1	<1	0.03	0.04
Londis Shop	26233	<1	<1	0.05	0.08
M Sheedy House* (beside Shop)	26234	<1	<1	0.08	0.08
Ann Lynch House* (beside creche)	26235	<1	<1	0.02	0.04
Darren Kelly House* (beside School)	26236	<1	<1	0.06	0.09

*On Request

Comment: No Coliforms or *E. coli* were detected in the samples tested. Please ensure to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.