

## **Drinking Water Quality Certification – February 2022**

Killone GWS,  
Imleach,  
Barntick,  
Ballynacally,  
Co. Clare.

**Report No:** 10171  
**Reference:** 37-73  
**Date Sampled:** 10 Feb 2022  
**Date Reported:** 12 Feb 2022

**Regulations:** SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	28625	<1	<1	0.16	0.20
R Murphy	28626	<1	<1	0.26	0.28
Michael Hogan	28628	<1	<1	0.28	0.30
School/Hall	28629	<1	<1	0.20	0.21
Londis Shop	28630	<1	<1	0.12	0.13

**Comment:** No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan  
Amberley Water Solutions Ltd.