

15/11/2015

Mr. Adrian Donnelly,  
Treasurer Killone GWS,  
Imleach,  
Barntick,  
Ballynacally,  
Co. Clare.

Report No. 7846  
Ref: 27-22

Dear Adrian,

**Re: Drinking Water Quality Certification – November 2015**

We examined six drinking water samples taken from the indicated locations on the 11/11/2015 to determine the level of compliance with the drinking water/food regulations on coliforms and chemical parameters indicated.

**Regulations:**

SI 278 of 2007 and the Drinking Water Directive.  
Food hygiene regulations

Sample location	Sample No.	Total coliforms No./100 mL	E. Coli No./100 mL	Residual free chlorine mg/L	Total chlorine mg/L
Pat Haren	19763	<1	<1	0.10	0.10
Andy Price	19764	<1	<1	0.11	0.11
Creche	19765	<1	<1	0.10	0.10
Michael Hogan	19766	<1	<1	0.20	0.20
School/Hall	19767	<1	<1	0.15	0.15
Sheedy's Shop	19768	<1	<1	0.12	0.12

**Drinking Water Quality Rating:** Please maintain free chlorine levels at a minimum of 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Sincerely,

Signed: 

Lorna Moynihan

Amberley Water Solutions Ltd.