

## **Drinking Water Quality Certification – December 2017**

Killone GWS,  
Imleach,  
Barntick,  
Ballynacally,  
Co. Clare.

**Report No:** 8540  
**Reference:** 30-97  
**Date Sampled:** 13 Dec 2017  
**Date Reported:** 18 Dec 2017

**Regulations:** SI 122 of 2014 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	22535	<1	<1	0.13	0.15
R Murphy	22536	<1	<1	0.26	0.32
Creche	22537	<1	<1	0.07	0.09
Michael Hogan	22538	<1	<1	0.16	0.20
School/Hall	22539	<1	<1	0.06	0.06
Sheedy's Shop	22540	<1	<1	0.07	0.10

**Drinking Water Quality Rating:** Please ensure to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan  
Amberley Water Solutions Ltd.