

Drinking Water Quality Certification – February 2018

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 8565
Reference: 30-146
Date Sampled: 20 Feb 2018
Date Reported: 25 Feb 2018

Regulations: SI 122 of 2014 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	22816	<1	<1	0.09	0.13
R Murphy	22817	<1	<1	0.66	0.72
Creche	22818	<1	<1	0.12	0.17
Michael Hogan	22819	<1	<1	0.63	0.69
School/Hall	22820	<1	<1	0.16	0.20
Sheedy's Shop	22821	<1	<1	0.11	0.19

Drinking Water Quality Rating: Please ensure to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.