

## **Drinking Water Quality Certification – July 2020**

Killone GWS,  
Imleach,  
Barntick,  
Ballynacally,  
Co. Clare.

**Report No:** 9400  
**Reference:** 34-143  
**Date Sampled:** 08 Jul 2020  
**Date Reported:** 14 Jul 2020

**Regulations:** SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	26404	<1	<1	0.06	0.08
R Murphy	26405	<1	<1	0.14	0.16
Creche	26406	<1	<1	0.06	0.08
Michael Hogan	26407	<1	<1	0.16	0.20
School/Hall	26408	<1	<1	0.04	0.05
Londis Shop	26409	<1	<1	0.06	0.07
M Sheedy House* (beside Shop)	26410	<1	<1	0.04	0.08
Ann Lynch House* (beside creche)	26411	<1	<1	0.04	0.07
Darren Kelly House* (beside School)	26412	<1	<1	0.08	0.09

\*On Request

**Comment:** No Coliforms or *E. coli* were detected in the samples tested. Please ensure to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan  
Amberley Water Solutions Ltd.