

Drinking Water Quality Certification – February 2020

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 9372
Reference: 34-58/60
Date Sampled: 04 Feb 2020
Date Reported: 09 Feb 2020

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L	Total Hardness mg/L CaCO ₃
Pat Haren	25835	<1	<1	0.07	0.10	155
R Murphy	25836	<1	<1	0.18	0.23	165
Creche	25837	<1	<1	0.00	0.01	145
Michael Hogan	25838	<1	<1	0.16	0.23	170
School/Hall	25839	<1	<1	0.03	0.07	165
Londis Shop	25840	<1	<1	0.06	0.08	140

Drinking Water Quality Rating: Please ensure to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.