

Drinking Water Quality Certification – December 2016

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 8214
Reference: 28-138
Date Sampled: 12 Dec 2016
Date Reported: 18 Dec 2016

Regulations: SI 122 of 2014 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	21120	<1	<1	0.25	0.25
Andy Price*	21121	<1	<1	0.10	0.14
Creche	21122	<1	<1	0.14	0.14
Michael Hogan	21123	<1	<1	0.11	0.14
School/Hall	21124	<1	<1	0.14	0.14
Sheedy's Shop	21125	<1	<1	0.17	0.17

*This sample was taken from R Murphy's House

Drinking Water Quality Rating: Please ensure to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.