

Drinking Water Quality Certification – June 2021

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 9825
Reference: 36-10
Date Sampled: 02 Jun 2021
Date Reported: 07 Jun 2021

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	27446	<1	<1	0.09	0.11
R Murphy	27447	<1	<1	0.28	0.33
Creche	27448	<1	<1	0.08	0.08
Michael Hogan	27449	<1	<1	0.33	0.36
School/Hall	27450	<1	<1	0.04	0.04
Londis Shop	27451	<1	<1	0.05	0.10

Comment: No Coliforms or *E. coli* were detected in the samples tested. It is recommended to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.