

Drinking Water Quality Certification – March 2017

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 8304
Reference: 29-45
Date Sampled: 21 Mar 2017
Date Reported: 28 Mar 2017

Regulations: SI 122 of 2014 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	21453	<1	<1	0.14	0.23
R Murphy	21454	<1	<1	0.17	0.20
Creche	21455	<1	<1	0.17	0.17
Michael Hogan	21456	<1	<1	0.15	0.15
School/Hall	21457	<1	<1	0.23	0.36
Sheedy's Shop	21458	<1	<1	0.10	0.10

Drinking Water Quality Rating: Please ensure to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.