

## **Drinking Water Quality Certification – September 2018**

Killone GWS,  
Imleach,  
Barntick,  
Ballynacally,  
Co. Clare.

**Report No:** 8780  
**Reference:** 31-142  
**Date Sampled:** 12 Sep 2018  
**Date Reported:** 23 Sep 2018

**Regulations:** SI 122 of 2014 and the Drinking Water Directive

| Sample Location | Sample No. | Total Coliforms No./100 mL | <i>E. coli</i> No./100 mL | Free Chlorine mg/L | Total Chlorine mg/L |
|-----------------|------------|----------------------------|---------------------------|--------------------|---------------------|
| Pat Haren       | 23628      | <1                         | <1                        | 0.07               | 0.09                |
| R Murphy        | 23629      | <1                         | <1                        | 0.17               | 0.27                |
| Creche          | 23630      | <1                         | <1                        | 0.06               | 0.07                |
| Michael Hogan   | 23631      | <1                         | <1                        | 0.17               | 0.25                |
| School/Hall     | 23632      | <1                         | <1                        | 0.07               | 0.09                |
| Sheedy's Shop   | 23633      | <1                         | <1                        | 0.07               | 0.09                |

**Drinking Water Quality Rating:** Please ensure to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan  
Amberley Water Solutions Ltd.