

Drinking Water Quality Certification – May 2019

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 9050
Reference: 33-2
Date Sampled: 16 May 2019
Date Reported: 26 May 2019

Regulations: SI 122 of 2014 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	24683	<1	<1	0.14	0.16
R Murphy	24684	<1	<1	0.44	0.48
Creche	24685	<1	<1	0.11	0.14
Michael Hogan	24686	<1	<1	0.36	0.40
School/Hall	24687	<1	<1	0.09	0.10
Sheedy's Shop	24688	<1	<1	0.09	0.10

Drinking Water Quality Rating: Please continue to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.