

Drinking Water Quality Certification – October 2021

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 10006
Reference: 36-138
Date Sampled: 08 Oct 2021
Date Reported: 17 Oct 2021

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	28073	<1	<1	0.24	0.28
R Murphy	28074	<1	<1	0.48	0.52
Creche	-	-	-	-	-
Michael Hogan	28076	<1	<1	0.44	0.48
School/Hall	28077	<1	<1	0.42	0.44
Londis Shop	28078	<1	<1	0.24	0.26

Comment: No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

The Creche was closed at the time of sampling.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.