

Drinking Water Quality Certification – July 2024

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 11402
Reference: 41-153
Date Sampled: 05 Jul 2024
Date Reported: 12 Jul 2024

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	33796	<1	<1	0.05	0.05
R Murphy	33797	<1	<1	0.09	0.09
Michael Hogan	33798	<1	<1	0.14	0.14
School	33799	<1	<1	0.10	0.10
Londis Shop	33800	<1	<1	0.09	0.09
Banner Steel	33801	<1	<1	0.07	0.07

Comment: No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.