

Drinking Water Quality Certification – May 2018

Killone GWS,
Imleach,
Barn tick,
Ballynacally,
Co. Clare.

Report No: 8657
Reference: 31-53
Date Sampled: 11 May 2018
Date Reported: 20 May 2018

Regulations: SI 122 of 2014 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	23157	<1	<1	0.14	0.21
R Murphy	23158	<1	<1	0.42	0.53
Creche	23159	<1	<1	0.12	0.19
Michael Hogan	23160	<1	<1	0.44	0.55
School/Hall	23161	<1	<1	0.12	0.14
Sheedy's Shop	23162	<1	<1	0.13	0.19

Drinking Water Quality Rating: Please ensure to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.