

### **Drinking Water Quality Certification – March 2019**

Killone GWS,  
Imleach,  
Barntick,  
Ballynacally,  
Co. Clare.

**Report No:** 8976  
**Reference:** 32-103  
**Date Sampled:** 11 Mar 2019  
**Date Reported:** 24 Mar 2019

**Regulations:** SI 122 of 2014 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	24352	<1	<1	0.11	0.19
R Murphy	24353	<1	<1	0.28	0.33
Creche	24354	<1	<1	0.10	0.14
Michael Hogan	24355	<1	<1	0.25	0.30
School/Hall	24356	<1	<1	0.07	0.09
Sheedy's Shop	24357	<1	<1	0.06	0.09

**Drinking Water Quality Rating:** Please ensure to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan  
Amberley Water Solutions Ltd.