

Drinking Water Quality Certification – November 2017

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 8518
Reference: 30-77
Date Sampled: 16 Nov 2017
Date Reported: 27 Nov 2017

Regulations: SI 122 of 2014 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	22445	<1	<1	0.11	0.12
R Murphy	22446	<1	<1	0.15	0.19
Creche	22447	<1	<1	0.10	0.14
Michael Hogan	22448	<1	<1	0.16	0.20
School/Hall	22449	<1	<1	0.07	0.07
Sheedy's Shop	22450	<1	<1	0.10	0.11

Drinking Water Quality Rating: Please ensure to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.