

Drinking Water Quality Certification – September 2022

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 10468
Reference: 38-101/106/119
Date Sampled: 12 Sep 2022
Date Reported: 19 Sep 2022

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	29668	<1	<1	0.17	0.17
R Murphy	29669	<1	<1	0.43	0.44
Michael Hogan	29670	<1	<1	0.44	0.47
School	29671	<1	<1	0.13	0.13
Londis Shop	29672	<1	<1	0.23	0.24
Banner Steel	29673	<1	<1	0.10	0.10

Comment: No Coliforms or *E. coli* were detected in the samples tested. It is recommended to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.