

Drinking Water Quality Certification – June 2019

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 9081
Reference: 33-22
Date Sampled: 13 Jun 2019
Date Reported: 22 Jun 2019

Regulations: SI 122 of 2014 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	24770	<1	<1	0.17	0.20
R Murphy	24771	<1	<1	0.28	0.33
Creche	24772	<1	<1	0.07	0.10
Michael Hogan	24773	<1	<1	0.20	0.23
School/Hall	24774	<1	<1	0.06	0.06
Sheedy's Shop	24775	<1	<1	0.09	0.10

Drinking Water Quality Rating: Please ensure to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.