

Drinking Water Quality Certification – January 2026

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 12080
Reference: 44-49/50
Date Sampled: 06 Jan 2026
Date Reported: 12 Jan 2026

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	36748	<1	<1	0.93	0.99
R Murphy	36749	<1	<1	1.42	1.52
Michael Hogan	36750	<1	<1	1.48	1.52
School	36756	<1	<1	0.86	0.91
Londis Shop	36751	<1	<1	0.84	0.90
Banner Steel	36752	<1	<1	1.10	1.20

Comment:

No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.