

Drinking Water Quality Certification – February 2017

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 8284
Reference: 29-22
Date Sampled: 21 Feb 2017
Date Reported: 26 Feb 2017

Regulations: SI 122 of 2014 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	21381	<1	<1	0.17	0.17
R Murphy	21382	<1	<1	0.14	0.14
Creche	21383	<1	<1	0.11	0.11
Michael Hogan	21384	<1	<1	0.16	0.20
School/Hall	21385	<1	<1	0.16	0.16
Sheedy's Shop	21386	<1	<1	0.14	0.14

Drinking Water Quality Rating: Please ensure to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.