

26/02/2015

Mr. Adrian Donnelly,
Treasurer Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No. 7592
Ref: 25-150

Dear Adrian,

Re: Drinking Water Quality Certification – February 2015

We examined six drinking water samples taken from the indicated locations on the 20/02/2015 to determine the level of compliance with the drinking water/food regulations on coliforms and chemical parameters indicated.

Regulations:

SI 278 of 2007 and the Drinking Water Directive.
Food hygiene regulations

Sample location	Sample No.	Total coliforms No./100 mL	E. Coli No./100 mL	Residual free chlorine mg/L	Total chlorine mg/L
Pat Haren	18921	<1	<1	0.30	0.30
Andy Price	18922	<1	<1	0.27	0.27
Creche	18923	<1	<1	0.32	0.32
Michael Hogan	18924	<1	<1	0.25	0.25
School/Hall	18925	<1	<1	0.27	0.27
Sheedy's Shop	18926	<1	<1	0.20	0.20

Drinking Water Quality Rating:

Please continue to maintain free chlorine levels at a minimum of 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Sincerely,

Signed: 

Lorna Moynihan

Amberley Water Solutions Ltd.