

Drinking Water Quality Certification –Apr 2024

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 11295
Reference: 41-66
Date Sampled: 03 Apr 2024
Date Reported: 18 Apr 2024

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Parameter	Results: Sample No. 33205	Specification
THM	48	100 µg/L

ND: Not Detected; *Not a specification for drinking water; recommended ranges for equipment & infrastructure

Comment: THM levels are within specification for drinking water.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.