

Drinking Water Quality Certification – October 2019

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 9236
Reference: 33-123/126
Date Sampled: 16 Oct 2019
Date Reported: 26 Oct 2019

Regulations: SI 122 of 2014 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L	Total Hardness mg/L CaCO ₃
Pat Haren	25370	<1	<1	0.13	0.16	165
R Murphy	25371	<1	<1	0.17	0.24	150
Creche	25372	<1	<1	0.07	0.10	160
Michael Hogan	25373	<1	<1	0.13	0.17	160
School/Hall	25374	<1	<1	0.17	0.17	160
Londis Shop	25375	<1	<1	0.12	0.14	150

Drinking Water Quality Rating: Please ensure to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.