

Drinking Water Quality Certification – September 2021

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 9963
Reference: 36-112
Date Sampled: 15 Sep 2021
Date Reported: 16 Sep 2021

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	27933	<1	<1	0.40	0.44
R Murphy	27934	<1	<1	0.78	0.80
Creche	-	-	-	-	-
Michael Hogan	27935	<1	<1	0.78	0.79
School/Hall	27936	<1	<1	0.58	0.64
Londis Shop	27937	<1	<1	0.10	0.12

Comment: No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

The Creche was closed at the time of sampling.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.