

Drinking Water Quality Certification – April 2017

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 8343
Reference: 29-68
Date Sampled: 14 Apr 2017
Date Reported: 19 Apr 2017

Regulations: SI 122 of 2014 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	21614	<1	<1	0.11	0.11
R Murphy	21615	<1	<1	0.10	0.10
Creche	21616	<1	<1	0.14	0.14
Michael Hogan	21617	<1	<1	0.14	0.14
School/Hall	21618	<1	<1	0.11	0.17
Sheedy's Shop	21619	<1	<1	0.13	0.15

Drinking Water Quality Rating: Please ensure to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.