

Drinking Water Quality Certification – April 2025

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 11760
Reference: 42-185
Date Sampled: 08 Apr 2025
Date Reported: 12 Apr 2025

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	-	-	-	-	-
R Murphy	35346	<1	<1	0.20	0.27
Michael Hogan	35347	<1	<1	0.33	0.53
School	35348	<1	<1	0.11	0.18
Londis Shop	35349	<1	<1	0.29	0.30
Banner Steel	35350	<1	<1	0.09	0.13

Comment: No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

Pat Haren wasn't home, so we were unable to sample.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.