

## **Drinking Water Quality Certification – September 2017**

Killone GWS,  
Imleach,  
Barntick,  
Ballynacally,  
Co. Clare.

**Report No:** 8446  
**Reference:** 30-18  
**Date Sampled:** 13 Sep 2017  
**Date Reported:** 20 Sep 2017

**Regulations:** SI 122 of 2014 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	22167	<1	<1	0.15	0.18
R Murphy	22168	<1	<1	0.15	0.16
Creche	22169	<1	<1	0.09	0.09
Michael Hogan	22170	<1	<1	0.10	0.11
School/Hall	22171	<1	<1	0.11	0.11
Sheedy's Shop	22172	<1	<1	0.11	0.11

**Drinking Water Quality Rating:** Please ensure to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan  
Amberley Water Solutions Ltd.